

The Butler Wastewater Treatment Facility had a CSO 003 start overflowing at 11:00 PM on 3/31/2026.
Flow stopped at 6:00 PM on 4/1/2026. Total gallons: 1.954 MGD

The Butler Wastewater Treatment Facility had a CSO 003 start overflowing at 5:40 PM on 8/6/2026.
Flow stopped at 8:05 PM on 8/6/2026. Total gallons: .655 MGD

A CSO (Combined Sewer Overflow) is when a combined sewer system that carries wastewater and stormwater in the same system overflows into a nearby stream. The system can be overloaded with heavy rainfall and/or snow melt causing partially treated or untreated wastewater/stormwater to discharge into nearby streams.

MGD- Million Gallons per Day

During the event of a CSO the public should avoid ingesting, swimming, or any other water activities in the big run creek due to the higher levels of pollutants.

Outfall	Location	Receiving Water
003	U.S. Hwy 6 Bridge 41° 25' 48" N 84° 51' 26" W	Big Run Creek