

SEWER & INFRASTRUCTURE NOTES - SEPTEMBER 10

-

IN ATTENDANCE: Mike Dvorchak, Robina Ward, Steve Tiger, Les Coon, Steve Bluestone

1. DEC visited last Thursday (Jamie Malcom). Les related that it was a smooth and positive inspection. Jamie alerted us to new limits on future permitting. We are testing to see where current levels are. There were minor issues involving the panel. Jamie did remark that the filters were very clean.
2. Reprogramming of Panel – Status
 1. Les reports that the panel has now been successfully reprogrammed. The temperature faulty reading has been evaluated. The Thermoster needs to be replaced. We need to check the warranty. Robina will check the purchase date.
3. We have purchased 3 new pumps to have on hand in case of emergencies.
4. Norton Property issues on Route 23 – this is not a sewer issue, caused by a resident and flushing of rags.
5. 47 Coldwater - Frozen pipes – still waiting to see how other municipalities are working with heat tape.
6. Baffles for tanks Wastewater – Robina and Mike will investigate options with Les.
7. Schedule of Tank Cleaning – proceeding on schedule
8. Harness and safety equipment – Robina will order.
9. SPDES Permit – we are testing new levels, and DEC is finalizing the new standards.
10. Engineering Grant – still waiting for her
11. Wi-Fi Alarm Status – Les did contact the other municipality and will follow up.
12. Emergency Contact List – The next mailing will include an emergency contact request.